

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

Violations Comments

<p>Violation #5. Maintenance & Repair</p> <ul style="list-style-type: none">-Observed peeling paint on column by #039 and by cafeteria. Scrape and paint.-Observed 1 missing ceiling tile inside classroom#41. Replace missing ceiling tile.-Observed loose baseboard by entrance door inside classroom #39. Secure loose baseboard.-Observed water-stained ceiling tiles inside classroom #K-1, K-2, K-3 & K-4. Replace ceiling tiles.-Observed signs of moisture on classroom window walls as evidenced by peeling/bubbly paint. Assess, scrape and paint. <p>CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.</p>
<p>Violation #11. Group Toilet Rooms</p> <ul style="list-style-type: none">-Observed 3 rusty handwashing sink bowls inside #056 Boys group restroom. Eliminate rust/replace handwashing sink. [Repeat violation from last routine inspection 12/11/23] <p>CODE REFERENCE: 11. Group Toilet Rooms. 5(16)(b)7 SREF. Group toilet rooms, where provided, shall meet the following requirements: 5(16)(b)7.a SREF. Entrances to group toilet rooms shall be provided with a partition or other shielding device to block occupants from view. 5(16)(b)7.b SREF. A partition shall be placed between each water closet. Water closet stalls shall be provided with doors. The partitions and doors shall be maintained in a safe, secure, and operational condition at all times. 5(10)(e) SREF. Toilet Partitions. Toilet compartments, partitions, and doors may be provided in other areas, such as locker rooms, and shall be finished with noncorrosive, impervious materials. 468.3.5.3.2 FBC. Access to student group toilet rooms shall not be through an occupied space, storage space, or equipment space. 468.3.5.6 FBC. All group toilet rooms shall be provided with at least one (1) floor drain and (1) hose bib. The floor shall be sloped to the drain. Stall urinals do not serve for the required floor drains.</p>
<p>Violation #12. Toilet Facilities</p> <ul style="list-style-type: none">-Observed missing wall tiles along with signs of moisture (peeling and bubbly paint) inside #001A clinic restroom. Assess and repair/replace.-Observed 1 out-of-order toilet (2nd from left) inside #034 Girls restroom. Repair/replace.-Observed unfinished wall bottom behind toilet inside classroom restroom#04. Complete repairs. Classroom is not being used at this time.-Observed 3 loose toilet seats inside Girls group restroom #57 (far right, far left and second from right). Secure toilet seat. <p>CODE REFERENCE: 12. Toilet Facilities. 5(16)(b)2.c SREF. Deodorizers shall not be used in toilet rooms. 5(10)(f) SREF. Toilet and bath accessories, including grab bars; toilet paper dispensers; paper towel dispensers or hot-air drying devices; napkin disposal units; shelving, and mirrors, where provided, shall be maintained in a safe and secure condition at all times. The use of common or public towels shall not be permitted. 5(13)(f)4 SREF. Toilet facilities shall have a nonslip, impervious floor, impervious base, and minimum four foot- high impervious wainscot. 5(13)(p)2 SREF. Each staff toilet room shall be provided with at least one water closet and one lavatory and shall be provided with hot and cold water at the lavatory. 5(14)(b)10.a SREF. Walls in toilet rooms shall be finished with impervious materials to a minimum height of four feet. Floor and base in individual or group toilet rooms shall be impervious. 468.3.5.4 FBC. The entry to each group toilet room shall be provided with a door, partition, or other shielding device to block from view the occupants in the toilet room. If a door is provided, it shall have a closer. 5(16)(b)1 SREF. Toilet facilities shall be maintained in a satisfactory state of repair at all times. 5(16)(b)2.a. SREF. Water closets, urinals, lavatories, faucets, flush valves, dispensers, partitions, lower half of walls, and floors shall be maintained in a clean & sanitary condition at all times.</p>
<p>Violation #18. Drinking Fountains</p> <ul style="list-style-type: none">Observed out of order drinking fountain (on left), by Boys restroom #032. Repair/replace. <p>CODE REFERENCE: 18. Drinking Fountains. 5(16)(b)9 SREF. Drinking fountains shall be maintained in an operational condition at all times. 5(1)(e)8.b SREF. Toilet rooms, shower and locker rooms, drinking water fountains, and clinics shall be cleaned & disinfected daily using an appropriate Germicidal Detergent. Note: Drinking fountains shall be rinsed or flushed with plain water after disinfection. 468.3.5.1 FBC. Educational & ancillary facilities shall have drinking fountains for all occupants, in ratios & accessible as required.</p>

Inspection Conducted By: Venus Fernandez (82515)
Inspector Contact Number: Work: (305) 623-3516 ex.
Print Client Name: Kristina Ibarra-Zamora
Date: 2/21/2025

Inspector Signature:

Client Signature: