



STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT



2 of 2

**Violations Comments**

<p>Violation #6. Lighting Standards Observed 1 burned-out ceiling light inside classroom #119. Replace burned-out bulb. CODE REFERENCE: 6. Lighting Standards. 468.3.2. FBC. Sources of natural light in instructional spaces shall be glazed with glare reducing materials or shall be shielded to prevent glare that can interfere with seeing task.</p>
<p>Violation #11. Group Toilet Rooms Observed handicap stall with "Out of service" sign due to leaking flushing valve inside #114 Girls and #113 Boys group toilet room. Repair/replace. Per PIC, there is a work order on file. CODE REFERENCE: 11. Group Toilet Rooms. 5(16)(b)7 SREF. Group toilet rooms, where provided, shall meet the following requirements: 5(16)(b)7.a SREF. Entrances to group toilet rooms shall be provided with a partition or other shielding device to block occupants from view. 5(16)(b)7.b SREF. A partition shall be placed between each water closet. Water closet stalls shall be provided with doors. The partitions and doors shall be maintained in a safe, secure, and operational condition at all times. 5(10)(e) SREF. Toilet Partitions. Toilet compartments, partitions, and doors may be provided in other areas, such as locker rooms, and shall be finished with noncorrosive, impervious materials. 468.3.5.3.2 FBC. Access to student group toilet rooms shall not be through an occupied space, storage space, or equipment space. 468.3.5.6 FBC. All group toilet rooms shall be provided with at least one (1) floor drain and (1) hose bib. The floor shall be sloped to the drain. Stall urinals do not serve for the required floor drains.</p>

Inspection Conducted By: Venus Fernandez (82515)  
Inspector Contact Number: Work: (305) 623-3516 ex.  
Print Client Name: V. Del Rio-AP  
Date: 2/21/2025

Inspector Signature:

Handwritten signature of the inspector.

Client Signature:

Handwritten signature of the client.